

490 East Industrial Park Drive
 Manchester, NH 03109
 www.nelsonanalytical.com
 (603)622-0200

NH ELAP Accreditation #NH1005
 Maine State Certification #NH01005
 Vermont State Certification # VT1005
 Maine Radon Certification # ME17500

Report of Analysis

Customer: Easter Seals	Date Collected: 03/29/2019 06:00 AM
Client Sample ID: Easter Seals	Collected By : J. Ottani
Laboratory ID: 119040015.01	Date Received : 03/29/2019 05:00 PM
Sample Matrix : Drinking Water	Temperature Rec'd °C: #20.0
Sample Location: Nurse Station, 1 & 9 Mammoth Road, Manchester, NH	

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer: Easter Seals	Date Collected: 03/29/2019 06:05 AM
Client Sample ID: Easter Seals	Collected By : J. Ottani
Laboratory ID: 119040015.02	Date Received : 03/29/2019 05:00 PM
Sample Matrix : Drinking Water	Temperature Rec'd °C: #20.0
Sample Location: Gloria Bath, 1 & 9 Mammoth Road, Manchester, NH	

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer: Easter Seals	Date Collected: 03/29/2019 06:08 AM
Client Sample ID: Easter Seals	Collected By : J. Ottani
Laboratory ID: 119040015.03	Date Received : 03/29/2019 05:00 PM
Sample Matrix : Drinking Water	Temperature Rec'd °C: #20.0
Sample Location: #202, 1 & 9 Mammoth Road, Manchester, NH	

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer: Easter Seals	Date Collected: 03/29/2019 06:12 AM
Client Sample ID: Easter Seals	Collected By : J. Ottani
Laboratory ID: 119040015.04	Date Received : 03/29/2019 05:00 PM
Sample Matrix : Drinking Water	Temperature Rec'd °C: #20.0
Sample Location: #203, 1 & 9 Mammoth Road, Manchester, NH	

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer: Easter Seals	Date Collected: 03/29/2019 06:15 AM
Client Sample ID: Easter Seals	Collected By : J. Ottani
Laboratory ID: 119040015.05	Date Received : 03/29/2019 05:00 PM
Sample Matrix : Drinking Water	Temperature Rec'd °C: #20.0
Sample Location: #204, 1 & 9 Mammoth Road, Manchester, NH	



Notes: mg/l=ppm; ug/l=ppb; "<" denotes "less than". ND= Non-detected. This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Customer Supplied information is the sample location, date, time, sampler and tests requested. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, and the Maine Laboratory Certification Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pH & Chlorine as field parameters and they should be tested immediately at sample collection. Samples tested for pH are analyzed beyond the hold time for the analysis. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. # Sample(s) received at laboratory do not meet method specified temperature criteria. Subcontracting Information: SUB2=NH2018(EPA-ME00015); SUB3=NH1004(EPA-NH00035) SUB4=NH2073, SUB5=NH2530 SUB6=NH2124 ME IN00035 SUB 7=NH1007 SUB8=NH2136 [http://www.maine.gov/dhhs/mecdc/environmental-health/dwpp/professionals/labCert.shtml](http://des.nh.gov/organization/divisions/water/dwgb/nhelap/http://healthvermont.gov/enviro/ph_lab/PublicHealthLaboratory.aspxhttp://www.maine.gov/dhhs/mecdc/environmental-health/dwpp/professionals/labCert.shtml)

490 East Industrial Park Drive
 Manchester, NH 03109
 www.nelsonanalytical.com
 (603)622-0200

NH ELAP Accreditation #NH1005
 Maine State Certification #NH01005
 Vermont State Certification # VT1005
 Maine Radon Certification # ME17500

Report of Analysis

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer:	Easter Seals	Date Collected:	03/29/2019 06:20 AM
Client Sample ID:	Easter Seals	Collected By :	J. Ottani
Laboratory ID:	119040015.06	Date Received :	03/29/2019 05:00 PM
Sample Matrix :	Drinking Water	Temperature Rec'd °C:	#20.0
Sample Location:	#205 Bath, 1 & 9 Mammoth Road, Manchester, NH		

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer:	Easter Seals	Date Collected:	03/29/2019 06:24 AM
Client Sample ID:	Easter Seals	Collected By :	J. Ottani
Laboratory ID:	119040015.07	Date Received :	03/29/2019 05:00 PM
Sample Matrix :	Drinking Water	Temperature Rec'd °C:	#20.0
Sample Location:	#207, 1 & 9 Mammoth Road, Manchester, NH		

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer:	Easter Seals	Date Collected:	03/29/2019 06:29 AM
Client Sample ID:	Easter Seals	Collected By :	J. Ottani
Laboratory ID:	119040015.08	Date Received :	03/29/2019 05:00 PM
Sample Matrix :	Drinking Water	Temperature Rec'd °C:	#20.0
Sample Location:	#208, 1 & 9 Mammoth Road, Manchester, NH		

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer:	Easter Seals	Date Collected:	03/29/2019 06:33 AM
Client Sample ID:	Easter Seals	Collected By :	J. Ottani
Laboratory ID:	119040015.09	Date Received :	03/29/2019 05:00 PM
Sample Matrix :	Drinking Water	Temperature Rec'd °C:	#20.0
Sample Location:	#209, 1 & 9 Mammoth Road, Manchester, NH		

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer:	Easter Seals	Date Collected:	03/29/2019 06:37 AM
------------------	--------------	------------------------	---------------------



Notes: mg/l=ppm; ug/l=ppb; "<" denotes "less than". ND= Non-detected. This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Customer Supplied information is the sample location, date, time, sampler and tests requested. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, and the Maine Laboratory Certification Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pH & Chlorine as field parameters and they should be tested immediately at sample collection. Samples tested for pH are analyzed beyond the hold time for the analysis. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. #-Sample(s) received at laboratory do not meet method specified temperature criteria. Subcontracting Information: SUB2=NH2018(EPA-ME00015); SUB3=NH1004(EPA-NH00035) SUB4=NH2073, SUB5=NH2530 SUB6=NH2124 ME IN00035 SUB 7=NH1007 SUB8=NH2136 [http://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/lab/Cert.shtml](http://des.nh.gov/organization/divisions/water/dwgb/nhelap/http://healthvermont.gov/enviro/ph_lab/PublicHealthLaboratory.aspxhttp://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/lab/Cert.shtml)

490 East Industrial Park Drive
 Manchester, NH 03109
 www.nelsonanalytical.com
 (603)622-0200

NH ELAP Accreditation #NH1005
 Maine State Certification #NH01005
 Vermont State Certification # VT1005
 Maine Radon Certification # ME17500

Report of Analysis

Client Sample ID: Easter Seals	Collected By :	J. Ottani
Laboratory ID: 119040015.10	Date Received :	03/29/2019 05:00 PM
Sample Matrix : Drinking Water	Temperature Rec'd °C:	#20.0
Sample Location: #201, 1 & 9 Mammoth Road, Manchester, NH		

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer: Easter Seals	Date Collected:	03/29/2019 06:42 AM
Client Sample ID: Easter Seals	Collected By :	J. Ottani
Laboratory ID: 119040015.11	Date Received :	03/29/2019 05:00 PM
Sample Matrix : Drinking Water	Temperature Rec'd °C:	#20.0
Sample Location: BGH Right Bath, 1 & 9 Mammoth Road, Manchester, NH		

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer: Easter Seals	Date Collected:	03/29/2019 06:45 AM
Client Sample ID: Easter Seals	Collected By :	J. Ottani
Laboratory ID: 119040015.12	Date Received :	03/29/2019 05:00 PM
Sample Matrix : Drinking Water	Temperature Rec'd °C:	#20.0
Sample Location: BGH Left Bath, 1 & 9 Mammoth Road, Manchester, NH		

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer: Easter Seals	Date Collected:	03/29/2019 06:49 AM
Client Sample ID: Easter Seals	Collected By :	J. Ottani
Laboratory ID: 119040015.13	Date Received :	03/29/2019 05:00 PM
Sample Matrix : Drinking Water	Temperature Rec'd °C:	#20.0
Sample Location: BGH Kitchen, 1 & 9 Mammoth Road, Manchester, NH		

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer: Easter Seals	Date Collected:	03/29/2019 06:54 AM
Client Sample ID: Easter Seals	Collected By :	J. Ottani
Laboratory ID: 119040015.14	Date Received :	03/29/2019 05:00 PM
Sample Matrix : Drinking Water	Temperature Rec'd °C:	#20.0
Sample Location: BGH Bath At Cafe, 1 & 9 Mammoth Road, Manchester, NH		



Notes: mg/l=ppm; ug/l=ppb; "<" denotes "less than". ND= Non-detected. This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Customer Supplied information is the sample location, date, time, sampler and tests requested. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, and the Maine Laboratory Certification Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pH & Chlorine as field parameters and they should be tested immediately at sample collection. Samples tested for pH are analyzed beyond the hold time for the analysis. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. #-Sample(s) received at laboratory do not meet method specified temperature criteria. Subcontracting Information: SUB2=NH2018(EPA-ME00015); SUB3=NH1004(EPA-NH00035) SUB4=NH2073, SUB5=NH2530 SUB6=NH2124 ME IN00035 SUB 7=NH1007 SUB8=NH2136 http://des.nh.gov/organization/divisions/water/dwgb/nhelap/http://healthvermont.gov/enviro/ph_lab/PublicHealthLaboratory.aspxhttp://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml

490 East Industrial Park Drive
 Manchester, NH 03109
 www.nelsonanalytical.com
 (603)622-0200

NH ELAP Accreditation #NH1005
 Maine State Certification #NH01005
 Vermont State Certification # VT1005
 Maine Radon Certification # ME17500

Report of Analysis

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer:	Easter Seals	Date Collected:	03/29/2019 07:00 AM
Client Sample ID:	Easter Seals	Collected By :	J. Ottani
Laboratory ID:	119040015.15	Date Received :	03/29/2019 05:00 PM
Sample Matrix :	Drinking Water	Temperature Rec'd °C:	#20.0
Sample Location:	BGH Elevator Bath, 1 & 9 Mammoth Road, Manchester, NH		

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Customer:	Easter Seals	Date Collected:	03/29/2019 07:08 AM
Client Sample ID:	Easter Seals	Collected By :	J. Ottani
Laboratory ID:	119040015.16	Date Received :	03/29/2019 05:00 PM
Sample Matrix :	Drinking Water	Temperature Rec'd °C:	#20.0
Sample Location:	2nd Floor Bath, 1 & 9 Mammoth Road, Manchester, NH		

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	04/03/2019 03:10	EPA 200.8	Primary	Within EPA Standard

Test Types: EPA Primary: Regulated by the EPA as a health related parameter
 EPA Secondary: Aesthetic parameter - not regarded as a health concern

Respectfully Submitted 

Andrew Nelson, Laboratory Director



Notes: mg/l=ppm; ug/l=ppb; "<" denotes "less than". ND= Non-detected. This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Customer Supplied information is the sample location, date, time, sampler and tests requested. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, and the Maine Laboratory Certification Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pH & Chlorine as field parameters and they should be tested immediately at sample collection. Samples tested for pH are analyzed beyond the hold time for the analysis. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. #-Sample(s) received at laboratory do not meet method specified temperature criteria. Subcontracting Information: SUB2=NH2018(EPA-ME00015); SUB3=NH1004(EPA-NH00035) SUB4=NH2073, SUB5=NH2530 SUB6=NH2124 ME IN00035 SUB 7=NH1007 SUB8=NH2136 [http://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml](http://des.nh.gov/organization/divisions/water/dwgb/nhelap/http://healthvermont.gov/enviro/ph_lab/PublicHealthLaboratory.aspxhttp://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml)